

***Annual Drinking Water Quality Report for 2022***  
***Town of Warwick – Wickham Village Water District***  
***Warwick, NY***  
***Public Water Supply ID# 3505663***

## **INTRODUCTION**

To comply with State regulations, Wickham Village Water District will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact the water Department, at (845) 986-0630. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled boards. The meetings are held at 7:30 PM, at the town hall at 132 Kings Highway. Please call (845) 986-1124 ext. 247 for meeting dates.

## **WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves 1147 people through 327 service connections. Our water source is four groundwater wells, three are inactive one active. One is located inside the pump house on Wickham Drive, the second one is located at the south end of Shepard Road, the third well is located at Wickham Lake and the fourth well is located behind the Wickham Drive pump house. one well located at Wickham Lake goes through cartridge filters to remove sediment. The water is treated with caustic soda for PH adjustment, and orthophosphate for corrosion control and chlorinated prior to distribution.

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is or will become contaminated. See "Table of Detected Contaminants" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from four drilled wells, three inactive one active. The source water assessment has rated these wells as having a medium to medium-high susceptibility to microbials, nitrates, industrial solvents, and other industrial contaminants. These ratings are due primarily to the close proximity of a SPDES permitted discharge facility (industrial/commercial facilities that discharge wastewater into the environment and are regulated by the state and/or federal government), the low-level residential activity and the waste site that are located in the assessment area. In addition, the wells draw

from an unconfined aquifer of unknown hydraulic conductivity and a confined aquifer with the estimated recharge area within the selected time of travel and the overlying soils are not known to provide adequate protection from potential contamination. While the source water assessment rates our wells as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State’s drinking water standards for microbial contamination. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted in the report.

## ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, is more than one year old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA’s Safe Drinking Water Hotline (800-426-4791) or the Orange County Health Department at (845) 291-2331.

Table of Detected Contaminants							
Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Units	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Copper (See note 1)	No	8/3/22	90 <sup>th</sup> - 0.327 Range 0.0281 - 0.778	mg/l	1.3	AL = 1.3	Corrosion of household plumbing
Barium	No	3/02/22	0.0095	mg/l	2	MCL = 2	Erosion of natural deposits
Sodium	No	6/1/22	60.6	mg/l	N/A	** (See health effects below)	Naturally occurring
Nickel	No	3/02/22	0.0008	ug/l	100	MCL = 100	Naturally occurring
Nitrate	No	4/21/22	2.01	mg/l	10	MCL = 10	Runoff from fertilizer use
Total Trihalomethanes (TTHM)	No	8/3/2022	15.7	ug/l	N/A	MCL = 80	By-product of drinking water chlorination needed to kill harmful organisms
Haloacetic acids (HAA5)	No	8/3/2022	5.44	ug/l	N/A	MCL = 60	By-product of drinking water disinfection needed to kill harmful organisms
Total Organic Carbon (TOC) (See note 2)	No	Monthly 2022	0.9 - 2.63	mg/l	N/A	N/A	Naturally present in the environment

Perfluorooctanoic Acid (PFOA)	No	4/21/22	2.38	ng/l	N/A	MCL = 10	Released into the environment from widespread use in commercial and industrial applications
-------------------------------	----	---------	------	------	-----	----------	---

**Notes:**

1 – The level presented represents the 90<sup>th</sup> percentile of the 10 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90<sup>th</sup> percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 10 samples were collected at your water system and the 90<sup>th</sup> percentile value was 0.327 mg/l. The action level for copper was not exceeded at any of the sites.

2-Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAA5s). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

\*\* Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets.

Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

**Definitions:**

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Milligrams per liter (mg/l):** Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/l):** Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Nanograms per liter (ng/l):** Corresponds to one part of liquid in one trillion parts of liquid (parts per trillion - ppt).

**WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

**IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

During 2022, our system was in compliance with applicable State drinking water operating, monitoring and reporting requirements.

## **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

## **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are several reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life.
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems, and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So, get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

## **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.